



Subject: False Alarm at Peterborough Facility, 1160 Monaghan Road

Date: Mar. 29, 2021

On Monday, March 29th at approximately 9:15 a.m. Peterborough Fire Services responded to a fire alarm at BWXT Nuclear Energy Canada's Peterborough plant. The alarm was determined to be a false alarm and there was no fire or activation of the sprinkler system. There was no health or safety risk posed to the public, employees or the environment.

We understand there is work being completed on the city water supply that is causing transient pressures, so it is likely we will experience additional false alarms as this work is completed. We will continue to keep our website up to date.

Update 1: Mar. 30, 2021 at approximately 2:15 p.m.

Update 2: Mar. 31, 2021 at approximately 10:45 p.m.

Update 3: Apr. 1, 2021 at approximately 4:18 p.m.

Update 4: Apr. 4, 2021 at approximately 6:45 a.m.

Update 5: Apr. 7, 2021 at approximately 3:45 a.m.

Update 6: Apr. 15, 2021 at approximately 6:48 a.m.

Update 7: Apr. 21, 2021 at approximately 6:18 a.m.

Update 8: May 9, 2021 at approximately 5:40 a.m.

Update 9: May 11, 2021 at approximately 12:15 a.m.

Update 10: May 12, 2021 at approximately 6:15 a.m.

Update 11: May 13, 2021 at approximately 5:45 a.m.

Update 12: May 20, 2021 at approximately 12:15 a.m. and 3:05 a.m.

Update 13: June 14, 2021 at approximately 1:50 a.m.

Update 14: June 24, 2021 at approximately 6:30 a.m.